

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2024/SZ/58  
To

Dated 09/02/2024

The Dy. Health Officer,  
Public Health Department, MCD,  
Central Zone, Lajpat Nager,  
New Delhi 110024.

**Sub:** - Regarding issuance of fire safety certificate in r/o M/s Mandem (Unit of Interbix Club House Pvt Ltd) Situated at S-1, **Ground Floor, (Left Part Portion)**, Eros Hotel American Plaza Nehru Place, New Delhi 110019

Sir,

This has reference to with **MHA Portal ID 2024011000327 dated 11/01/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 05.02.2024 in the presence of Mr. Nishant to verify the fire safety measures installed in the building and observed that restaurant running at Ground Floor only. During inspection, following points were observed:

1. Some of the Sprinkler head found under /covered with the false ceiling. Sprinkler system working could not be verified due to the non availability of sprinkler testing value.
2. Exit Signage found removed at strategic location.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE