



C-112

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6 /DFS/MS/Hospital/NDZ/2024/ 53

Dated: 5/02/2024

To,

The Manager,  
Metro Hospital & Cancer Institute  
Plot No. 21, Community Centre, Preet Vihar,  
Delhi-110092.

**Sub: - Regarding grant of Fire Safety Certificate in r/o Metro Hospital & Cancer Institute Plot No. 21, Community Centre, Preet Vihar, Delhi - 110092.**

Sir,

This has a reference to your outdoor dairy no. 11997 dated 17.01.2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 02/02/2024 in the presence of Mr. Rajeev Tyagi (Manager) and observed that building comprised of two basement, upper ground plus three upper floors.

1. The electrical shafts are not sealed.
2. The first-aid-Hose Reels not provided on third floor.
3. MOEFA system provided but found not functional.
4. PA system provided but found not functional.
5. The exit signages are not provided at appropriate locations.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE  
o/c (e)

Copy to: -

1. The Manager, Metro Hospital & Cancer institute Plot No. 21, community centre preet vihar, Delhi- 110092.
2. The Exective Engineer (Bldg), Municipal Corpration of Delhi, Plot no. 419, Patparganj Industrial Area, Delhi -110092.