



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No. F6 /DFS/MS/Industrial/SZ/2024/43

Dated: 14/02/2024

To,

The Authorized Signatory,
M/s Kartar Infotech Private Limited,
A-25, (Lower Ground floor), Mohan Co-operative Industrial Estate,
Mathura Road, New Delhi-44.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Plot No. A-28, Mohan Co-operative Industrial Estate, Mathura Road, New Delhi-44.

Sir,

With reference to letter bearing outdoor diary no.11986 dated 17.01.2024 on the subject cited above, it is informed that the said building was inspected by a team of officers concerned of this department on 02.02.2024 in the presence of manager and it was observed that the building is comprised of Ground + 02 upper floors. During the inspection following shortcomings were observed:

1. Mechanical ventilation system provided in the building was found non functional and was not integrated with the Manually Operated Electrical Fire Alarm System (MOEFA).
2. Management is **advised** to secure all internal exits (to staircases) at every floor with Fire Check Doors (FCD) considering the bulk quantity of combustibles at floors.

In view of above shortcoming (at serial no.1), the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New Delhi-24.