

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

Dated: 12/02/2024

No. F. 6. / DFS / MS / BP / 2024/ 39

To,

The Executive Engineer, (Bldg) HQ,  
Municipal Corporation of Delhi,  
9<sup>th</sup> Floor Civic Centre, Minto Road,  
New Delhi-110002.

**Sub: Online building plans in r/o Plot No. T-2311, Ashok Nagar, Known as Ashoka Pahari, Faiz Road, Karol Bagh, New Delhi – 110005.**

Sir,

Please refer your Online Request ID No. 10118045 dated 30/01/2024 on the subject cited above. In this connection it is to inform you that online building plans have been scrutinized by this department from fire and life safety point of view and observed that there is a proposal of construction of a Mercantile Building at Plot No. T-2311, Ashok Nagar, Known as Ashoka Pahari, Faiz Road, Karol Bagh, New Delhi – 110005.

During scrutiny following shortcomings are observed:

1. Staircases, serving from basement are not segregated on stilt floor.
2. Smoke management system is not proposed in basement.

Therefore, the proposal is rejected.

Yours faithfully

(ATUL GARG)  
DIRECTOR  
Ph.: 011-23414000

 