

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**



No. F6/DFS/MS/WZ/2024/42  
To,

Dated: 14 / 02 / 2024

Dr. Saurabh Kumar (Head of Office),  
SRHC Hospital, Narela,  
Delhi- 110040.

**Sub: - Inspection report in r/o M/s. Satyawadi Raja Harishchandra Hospital, Plot No. 30, Sec. 7 A, Narela, Delhi- 110040.**

Sir,

Please refer to your e-mail id dated 17/01/2024 on the subject cited above. In this connection, it is to inform you that the above said building was re-inspected by the officer concerned of this department on 02/02/2024 in the presence of Sh. S.N. Sharma (Supervisor, Electrical) to verify the compliance of shortcomings communicated vide this department letter No. F6/DFS/MS/2023/Hospital/WZ/4009 dated 13/10/2023.

The status of shortcomings are as under:-

Sr. No	Shortcomings	Status
1.	Internal Road of 6 m found obstructed by new construction.	Not Rectified
2.	First Aid Hose Reels found provided but not functional.	Rectified
3.	Smoke/ Heat detectors provided but not functional.	Not Rectified
4.	MOEFA found provided but not functional.	Rectified
5.	Internal hydrants & Yard hydrants found provided but not functional.	Not Rectified
6.	Pumping system not found in auto mode.	Rectified

In view of the above shortcomings, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/ Occupier.

Yours faithfully,

(Atul Gang)  
Director

Ph. 011-23414000