



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/2024/SZ/52

Dated: 15/02/2024

To

Ms. Indrani Bose, Dy. Director,  
NFDC (A Govt. of India Enterprise),  
4<sup>th</sup> Floor, Sookhna Bhawan,  
Lodhi Road, New Delhi-110003

**Sub: Regarding renewal of Fire Safety Certificate in r/o Siri Fort Auditorium, August  
Kranti Marg, New Delhi-110049**

Sir,

This has reference to your letter no. 69/21/2012-FFD (SD) dated 05/01/2024 received through outdoor diary no. 11818 dated 12/01/2024. In this connection, the said premise was inspected by the team of officers of this department on 05/02/2024 in the presence of Sh. Om Prakash, AE (Elect-P). During the course of inspection, the shortcomings observed are as below.

1. The Automatic fire detection & alarming system found provided in Auditorium-1, 3 & 4 but non-functional and not provided in Auditorium-2.
2. MOEFA/MCPs system found provided but non-functional.

In view of the above shortcomings, the application for renewal of fire safety certificate is rejected. You are requested to rectify the above shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The General Manager (North), NFDC, Sookhna Bhawan, Lodhi Road, New Delhi-110003
2. The Assistant Engineer (Elect.), CCW AIR, Siri Fort Auditorium, New Delhi-110049