



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



C-169

No. F6 /DFS/MS/Hospital/SZ/2024/50

Dated: 15/02/2024

To

The Medical Superintendent,
M/s Vidyasagar Institute for Mental Health & Nero Allied Sciences,
No. 1, Institutional Area,
Nehru Nagar, New Delhi-65.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Vidyasagar Institute for Mental Health & Nero Allied Sciences, No. 1, Institutional Area, Nehru Nagar, New Delhi-65.

Sir,

With reference to the letter bearing outdoor diary no. 10614 dated 07.12.2023 on the subject cited above, it is informed that the said building was inspected by a team of officer concerned of this department on 02.02.2024 in the presence of Mr. Parmod Tripathi (Manager) and following shortcomings were observed:

1. Vertical & horizontal opening found non sealed.
2. Ventilation (Mechanical) non as per standards.
3. Hose reel & Internal hydrants found non functional.
4. Manual Operated Electrical Fire Alarm (MOEFA) system found not functional.
5. Automatic sprinkler system in the basement found non functional.
6. The provided main fire pump is not meeting the requirements (Discharge of 1620 LPM with 70 mtrs head is required against the available discharge of 1200 LPM with 65 mtrs head)
7. The head of jockey pump shall be 70 mtrs.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

14/2/24