

C 47

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2024/College/38

Dated: 14/02/2024

To,

The Principal,  
DPC Institute of Management Institutional Area  
Sector-09, Dwarka, New Delhi - 110077.

**Subject: Renewal of Fire Safety Certificate in r/o DPC Institute of Management Institutional Area Located at Sector-09, Dwarka, New Delhi - 110077.**

Sir,

Please refer to your letter No. Form J, dated 22/01/2024 on the subject mentioned above. In this connection it is to inform you that the premise was re-inspected by the officer concerned of this department on 06/02/2024 in presence of Sh. Sanjeev Bhardwaj (Asst. Director) from fire safety point of view.

During the course of inspection following shortcomings are observed.

1. All the stairs must be clear from any obstruction and must be free from lock and keys.
2. Fire check doors found removed/damaged at some places.
3. Hose reel hose & hydrants found nonfunctional.
4. Hoses and branches are found missing at some places. All hoses, branches & hose fittings must be ISI marked
5. Sprinkler system in basement found nonfunctional.
6. Pumps provided in the basement found nonfunctional in auto mode
7. Terrace fire pumps found nonfunctional and not in auto mode & all the valves are found closed at terrace.
8. Exit signage's found removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to comply the above mentioned shortcomings under intimation with this department for further consideration in the matter.

(Atul Garg)  
Director  
Delhi Fire Service

13/2/24  
01/2/24

Copy to; -

1. The Joint Director, DDA, INA, Vikas Sadan, New Delhi.