

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2024/SZ/ 51
To

Dated: 14/02/2024

The Joint Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony,
New Delhi 110049

Sub: Regarding issuance of FSC in r/o M/s DEL INN located at Kh. No 415-1 & 415-2,
A Block, Mahipalpur New Delhi 110037.

Sir,

This has reference with **MHA Portal ID 2024011900638 Dated 25/01/2024** on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 07/02/2024 in the presence of Mr. Gautam Kumar. During the inspection, it was observed that the building comprised of Basement + Ground + 04 upper floors. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The building is accessible through less than 06 mtr wide motorable road.
2. The width of corridor shall be 1.50 mtr for single loaded and 1.80 mtr for double loaded as per clause 7.11.2 of UBBL 2016.
3. Smoke ventilation system not provided as per clause 7.31 of UBBL 2016.
4. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.
5. Exit signage found not provided.
6. The occupancy above 3rd floor is not acceptable as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

01/11/24