

d56



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/WZ/2024/ School | 55

Dated:- 14/02/2024

To,

The Principal,
Govt. Sarvodaya Kanya Vidyalaya,
Ranhaul, New Delhi-110041.

Subj.:- Regarding renewal of Fire Safety Certificate in respect of Govt. Sarvodaya Kanya Vidyalaya (ID-1617005), located at Ranhaul, New Delhi-110041.

Sir,

Please refer to your email dated 03/02/2024 on the subject cited above. In this connection, it is to inform you that the above said school building was re-inspected by the officer concerned of this department on 07/02/2024 in the presence of Sh. Janardan (Estate Manager). During inspection, it has been observed that the school building is comprised of 04 blocks - Ground + 01 upper floor. However, the following shortcoming has been observed:-

1. Electrical meters/panels found under the staircases same shall be shifted on another safe place.

In view of the above, the application for renewal of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcoming under intimation to this department for taking further necessary action.

Yours faithfully,

(Atul Garg)
Director

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.

08/02/24