

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2024/SZ/48

Dated: 09/02/2024

To
The Addl. Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony,
New Delhi 110049.

Sub: Regarding issuance of FSC in r/o M/s Hotel Corporate Point Guest House, (A Unit of Tribhuvan Hotels Pvt. Ltd.) located at A-2/7Africa Avenue Marg, Safdarjung Enclave, New Delhi-110029.

Sir,

This has reference with letter received through **MHA Portal ID 2024012200695** dated **26/01/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 05.02.2024 in the presence of Mr. Brijesh Tyagi (Manager) and observed that the guest house running at 1st 2nd & 3rd upper floors with 19 G/Rooms to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire check doors not provided in the building as per clause 7.31 of UBBL 2016.
2. Smoke ventilation system not provided in the building as per clause 7.31 of UBBL 2016.
3. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

