

c 22

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI- 110001**

No. F6/DFS/MS/WZ/EH/2024/65

Dated: 16/02/2024

To,

The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi.  
[adlcp.lic-dl@nic.in](mailto:adlcp.lic-dl@nic.in)

Subject: Regarding issuance of NOC from fire safety point of view in respect of M/s. House of Royal (A unit of Greeting Hospitality), Located at Shop No: - 2, 4<sup>th</sup> floor, Vishal, Rajouri Garden, New Delhi-110027.

Sir,

This is in reference to the online application received through MHA portal vide online ID No. 2024011800585 dated 18/01/2024 on the subject cited above. In this connection, it is to inform you that the premises was re inspected by officer concerned of this department on 01/02/2024 in the presence Sh. Mukesh (Supervisor) to check the shortcomings already issued by this deptt. vide letter No.- F6/DFS/MS/WZ/EH/2024/23 dated: 12/01/2024.

During inspection, it has been observed that the above said restaurant is running at fourth floor in a building comprised of two basement, ground plus five upper floors. Fire safety arrangements such as Fire Extinguishers, Smoke Management system, First Aid Hose Reels, Automatic fire detection and alarming system, Internal Hydrants, Pumping Arrangements etc provided. However the status of shortcomings is as under.

S. no.	Shortcomings	Status
1.	Automatic fire detection and alarming system is provided but not functional.	Rectified but battery backup is not provided.
2.	MOEFA is provided but not functional.	Rectified
3.	Exit signages is not provided.	Not Rectified

In view of above Shortcomings the application for Issuance of Fire safety Certificate is not considered at this stage & rejected. The occupancy of the Building/premises in absence of requisite fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,

  
(Atul Garg)  
Director

Copy to: -

1. The Owner/Occupier, Ms House of Royal (A unit of Greeting Hospitality), Located at Shop No: - 2, 4<sup>th</sup> floor, Vishal, Rajouri Garden, New Delhi-110027. (online application no. 2024011800585 dated 18/01/2024)
2. The DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi-110027. Email Id : - ([dhowestzone@gmail.com](mailto:dhowestzone@gmail.com)).