

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/ 57

Dated: 14/02/2024

To

The Authored Signatory,
K. R Mangalam Global School,
N Block, Greater Kailash Part - 1,
New Delhi 110048.

Sub: -Regarding Issuance of Fire Safety Certificate in r/o K. R Mangalam Global School,
at N Block, Greater Kailash Part - 1, New Delhi 110048.

Sir,

This has reference to your letter no nil dated 08/11/2023, received through outdoor diary no 8436 dated 08/11/2023 on the subject above. In this connection, it is to inform you that the officers concerned of this department inspected on dated 05/02/2024 to check the compliance of fire safety arrangements from fire safety point of view Mr. Uma Shankar. Following shortcomings were observed:

1. Fire Check Doors found removed at some places.
2. The Smoke Management System in Basements & upper floors not working
3. Temporary Structure at terrace level is not allowed.
4. The basement cannot be used for any work other than parking.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

o/n