

 **GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

C 20



NO. F-6/DFS/MS/EH/WZ/2024/57

Dated:- 09/02/2024

To,

Smt. Vinni Khanna,  
M/s. Lala Shivnath Rai Sumerchand Confectioner Pvt. Ltd.,  
Shop No. 5, Ground Floor, Vaishali Main Road No- 41,  
Delhi- 110034.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Lala Shivnath Rai Sumerchand Confectioner Pvt. Ltd., Shop No. 5, Ground Floor, Vaishali Main Road No- 41, Delhi- 110034.

Sir,

Please refer to MHA application ID 2024011800592 dated 19.01.2024 on the subject cited above. Above said eating house running at ground floor of a building comprised of Basement, ground plus three upper floors. In this connection it is to inform you that the above said assembly building (Restaurant) was inspected by the officer concerned of this department on 02.02.2024 in presence of Mr. Aditya to check the fire safety measures provided in the building.

During the course of inspection it has been observed that fire safety arrangements such as fire extinguishers found provided, However the following shortcomings have been observed:-

- 1 Basement floor is not compartmentalized/ segregated providing fire check door.
- 2 The width of exits is 1.66 m & 0.90 m instead requirements of 1.5 m each.
- 3 Smoke management system is not provided.
- 4 First Aid Hose reel provided but not functional.
- 5 MOEFA is not provided.
- 6 Internal Hydrant provided but not functional.
- 7 Terrace pump of capacity 450 LPM found provided but not functional.
- 8 Overhead water Tank of 10,000 ltrs capacity provided against the requirement of 20,000 ltrs capacity.
- 9 Exit signages are not provided.

In View of the above, the application for issuance of Fire Safety Certificate is not considered at this stage and rejected. You are requested to re-apply on MHA portal as and when site is ready for inspection.

Yours faithfully



(Atul Garg)  
Director

Ph: 011-23414000

Copy to:-

1. The Joint Commissioner of Police, Licensing Unit, 1<sup>st</sup> Floor, Police Station, Defence Colony, New Delhi- 110049.
2. MHA Portal ID No. 2024011800592.

