



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/02
आफ़ादीन
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2024 | 56

Dated: 14/02/2024

To

The Principal,
M/s National Public School,
Kalindi Colony, Maharani Bagh, New Delhi-65.

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s National Public School located at Kalindi Colony, Maharani Bagh, New Delhi-65.

Sir,

This has reference to letter bearing outdoor diary no. 12564 dated 01.02.2024 on the subject cited above. In this context it is informed that the said building was inspected by the officer concerned of this department on 08.02.2024 in the presence of Mrs. Monika Kapoor (Principal) and it was observed that school building is comprised of Two block: Block A - Ground + 03 upper floors & Block B - Ground + 02 upper floors. During the inspection following shortcoming were observed:-

1. Hose reel found non functional
2. Fire pump of 450 LPM with 40 mtrs discharge shall be provided.
3. Overhead tank capacity of 10,000 liters shall be provided.
4. Exit sinages not adequate.

In view of above shortcomings, the application renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Anil Garg)
Director

Delhi Fire Service

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

01/2/24 w