

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

0115

7
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/WZ/2024/ School | 53

Dated:- 14/02/2024

To,

The Principal,
North Delhi Nagar Nigam Vidyalaya (ID-1556392),
New Multan Nagar, Keshav Puram Zone, Delhi-110056.

Subj.:- Regarding renewal of Fire Safety Certificate in respect of North Delhi Nigam Vidyalaya (ID-1556392), located at New Multan Nagar, Keshav Puram Zone, Delhi-110056.

Sir,

Please refer to your letter no. nil dated 15/12/2023 received in this department outdoor diary no. 10894 dated 15/12/2023, on the subject cited above. In this connection, it is to inform you that the above said school building was re-inspected by the officer concerned of this department on 08/02/2024 in the presence of Sh. Sunil Drall (Teacher). During inspection, it has been observed that the school building is comprised of Ground + 01 upper floor. However, the following shortcoming has been observed:-

1. Electrical meters/panels found under the staircases same shall be shifted on another safe place.

In view of the above, the application for renewal of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcoming under intimation to this department for taking further necessary action.

Yours faithfully,

(Atul Garg)
Director

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.

Handwritten signature and date: 08/02/24