

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/2024/SZ/58
To

Dated: 16/02/2024

Mr. Shamsheer Singh (Manager)
M/s Raja Towers Pvt Ltd,
601-A, Raja House, 30-31,
Nehru Place, New Delhi 110019

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Raja House, Building No 30-31 at Nehru Place, New Delhi- 110019.

Sir,

This has reference with letter no nil dated 21/01/2024, received through outdoor diary no 12496 dated 31/01/2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said building have been carried out by the officer concerned of this department on 09/02/2024 in the presence of Mr. Shamsheer Singh (Manager) and observed to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. The Fire Check door found removed at some places.
2. Fireman switch found removed in lift lobby.
3. Electrical meter install in the lift lobby area is not acceptable.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Handwritten initials