



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

c/38



No. F6/DFS/MS/2024/School/ 52

Dated: 14/02/2024

To,

The Principal,  
Sarvodaya Vidyalaya New Police Line,  
Kingsway Camp, Delhi-110009.

**Sub:-** Regarding renewal of fire safety certificate in r/o Sarvodaya Vidyalaya located at New Police Line, Kingsway Camp, Delhi-110009.

Sir,

Please refer to your letter received through online e-mail dated: 01.02.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 06.02.2024 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of Ground & 03 upper floors only. At the time of inspection Mr. D.C. Mehar (Vice- rincipal) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Hose reel hose provided but not functional and some nozzles found missing.
2. Internal hydrant provided but not functional and damaged condition.
3. Terrace level fire pump capacity of 450lpm provided but found not functional.
4. Terrace level fire water tank 5,000ltr provided against the requirements of 10,000ltr.
5. Exit signage's found removed at strategic locations in the school building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Atul Gang)  
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi, Old Sectt. Delhi - 110054.