

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F.6/DFS/MS/Educational/SZ/2024/CC/40

Dated: 20/02/2024

To,

Ms. Anju (Owner),
Property No. A-1/20,
Janakpuri, New Delhi-110058.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Property No. A-1/20, Janakpuri, New Delhi-110058.

Sir,

Please refer to your letter No. Nil, dated 01.02.2024, received in this department vide outdoor diary No. 12545 dated 01.02.2024, on the subject cited above. In this connection this is to inform you that officers concerned of this department inspected the premises on dated 09.02.2024 to verify the fire safety arrangements in accordance with the Delhi Fire Service Act, 2007 and Rules 2010. At the time of inspection Sh. Anurag was present and it was observed that the building is comprised of Basement (Vacant) Stilt (Parking), First, Second & Third floors (Coaching center) and have following shortcomings:-

- Fire Check doors not provided at some places.
- Smoke Management/ventilation system not provided in basement.
- Underground water Tank & fire pumps as per IS 15105 not provided.
- Exit signage's are provided but not sufficient.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully


(Atul Gang)
Director
Delhi Fire Service


Copy to:-

The Exicutive Engineer, MCD, Civic Centre, Minto Road, New Delhi.