

C-69

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/SZ/2024/ 59

Dated: - 20/02/2024

To,

The Principal,
Brain International School, H- Block,
Near Lal Market, Vikaspuri, New Delhi:- 110018.

Sub.:- Regarding renewal of Fire Safety Certificate in r/o Brain International School located at H- Block, Near Lal Market, Vikaspuri, New Delhi:- 110018..

Sir,

With reference to your letter received on dated 03.02.2024 through online E-mail Id abcfiresystems@hotmail.com, on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officers concerned of this department on 07.02.2024 in the presence of Sh. Suresh Kumar (Admin.) to check the fire safety arrangements provided in the school building.

During the course of inspection, it was observed that the school building is comprised of Basement, ground floor plus two upper floors. Fire safety arrangements such as hose reel, fire extinguishers etc. found provided in the school building. However, the following shortcomings were observed:-

1. Rooms constructed over the roof either should be removed or may be regulised through building sanctioning authority.
2. Fire check door found removed in basement floor.
3. Ventilation system found removed in basement.
4. Two terrace fire pump capacity of 450 LPM each found provided but not functional in auto mode.
5. Exit signage found removed.
6. The basement has been divided in numbers of class rooms.

In view of the above, 'Fire Safety Certificate' cannot be renew at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully


(Atul Garg)

Director

Delhi Fire Service

9/2/24

Copy to: -

The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-54.

For information please.