

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/2024/SZ/ 65
To

Dated: 20/02/2024

Goverdhan House Flat owners
& Occupiers Society (Regd.)
Goverdhan House, Building No 53-54
Nehru Place, New Delhi- 110019

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Goverdhan House,
Building No 53-54 at Nehru Place, New Delhi- 110019

Sir,

This has reference with letter no nil dated 17/08/2023, received through outdoor diary no 5018 dated 17/08/2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said building have been carried out by the officer concerned of this department on 09/02/2024 in the presence of Mr. J. K Tyagi and observed to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. The Fire Check door found removed at some places.
2. Detector system not provided in the flats / cabins.
3. Fire fighting pumps are not on auto mode.
4. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

ATUL V