No. F6/DFS/MS/BNQT/WZ/2024/ 20

To,

Dated: 20/02 /2024

The Dy. Health Officer (West Zone), NDMC, Public health department, Karol Bagh Zone, Anand Parbat, New Delhi -110005. Email Id: - (dhowest zone@gmail.com).

Subject: Regarding renewal of FSC/NOC in r/o. Grand Imperia (A unit of Sun Hospitality Grand Plaza), shop/property no.- No. 33/33A, Ground Floor, Rama Moti Nagar, New Delhi-110015.

Sir,

Please refer to your online application no. 2023020301480 dated 21/01/2024 received through MHA portal, on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 13/02/2024 in the presence of Sh. Ayush madan to check the functioning of fire safety arrangements provided in the building.

During inspection, it has been observed that the said Banquet Hall is running at Ground floor in a building comprised of Basement + Ground + 01 upper floor. Fire safety arrangements such as fire extinguishers, first -aid hose reel, MOEFA, internal hydrant, pumping arrangements, water storage tank etc. have been provided in the building. However, the following shortcomings were observed.

- 1. First-Aid Hose Reels are provided but found damaged at some places.
- 2. MOEFA is provided but not functional.
- 3. Terrace level fire pump capacity of 900lpm & jockey pump capacity of 180 lpm is provided but not functional.
- Exit Signages are not provided.

In view of above shortcomings the application for renewal of fire safety certificate is rejected. The occupancy of the building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier. The license issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire Safety arrangements.

Copy To:-1. The Owner/Occupier of M/s Grand Imperia (A unit of Sun Hospitality Grand Plaza), shop/property no.- No. 33/33A, Ground Floor, Rama Moti Nagar, New Delhi-110015.