



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7
आप्लादी
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2024 69

Dated: 20/02/2024

To
The Principal,
M/s Grow Big School, K-61, Thokar No. 5,
Abul Fazal Enclave-I, Okhla New Delhi-25.

Sub:- Regarding issuance of Fire Safety Certificate in r/o M/s Grow Big School located at K-61, Thokar No. 5, Abul Fazal Enclave-I, Okhla New Delhi-25.

Sir,
With reference to letter no. GBS/01/2023-24 dated 29.01.2024 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 14.02.2024 in the presence of Mrs. Raoos Fatima (Principal) and it was observed that the building is comprised of Ground + 04 upper floors. During the inspection following shortcomings were observed:-

1. 2 nos. of staircases 1.50 meters width each not provided in the building.
2. First aid hose reels not provided at each floor.
3. Fire pump of 450 LPM with head 40 m not provided.
4. Terrace water tank of 10,000 liters not provided (exclusively for firefighting).
5. Exit signages not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

15/2/24 M