

0/98

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI - 110001**

No.F6/DFS/MS/SZ/2024/ 60

Dated: 19/02/2024

To

The Addl. Commissioner of Police,  
Licensing Unit 1st Floor,  
P.S Defence Colony,  
New Delhi-110049

**Subject: - Renewal of Fire Safety Certificate in respect of M/s Hotel Pooja Palace, Located at 15A/11, WEA, Karol Bagh, New Delhi-110005.**

Sir,

Please refer to online application No. 2024020301197, dated 05/02/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 12/02/2024 in the presence of Sh. Manish Chawla (Owner) from fire safety point of view.


During the course of inspection following shortcomings were observed:

1. One hour Fire rating Fire Check Doors must be provided in basement.
2. CO Detectors must be provided in entire guest house.
3. Communication system in lift car found removed.
4. Electric panel installed in basement must be shifted at another place away from stairs/passage.
5. 4<sup>th</sup> floor (Tin shed) found erected and not shown in the plan.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully

  
(Atul Garg)  
Director  
Delhi Fire Service

  
19/2/24

Copy to: - The Manager, M/s Hotel Pooja Palace, Located at 15A/11, WEA, Karol Bagh, New Delhi-110005.