

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/2024/Hospital/WZ/ 62

Dated: 19/02/2024

To,

Sh. Mohd. Iqbal,
Assistant Engineer (Electrical),
Dr. BSA Hospital,
Sec-6, Rohini, Delhi-85.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Maharishi Valmiki Hospital, Pooth Khurd, Delhi-39.

Sir,

This has reference to your e mail id dated 15/01/2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said Hospital building has been carried out by officers concerned of this department on 10.02.2024 to see the compliance of the requisite fire safety measures. Sh. Amit Kumar was present at the time of inspection.

During the course of inspection it was observed that the building comprised of Basement, Ground & Three upper floors. Your request for renewal of FSC is rejected as the following shortcomings were observed:

1. There are only 3 staircases reaches up to terrace against the requirement of 08 staircases up to terrace.
2. Lift and staircases are not segregated with fire check door/ removed.
3. Smoke ventilation system in basement found removed.
4. Rectification of Fire Safety Arrangements is under progress.
5. MOEFA and P.A. system found provided and not functional.
6. Over Head water tank found empty.
7. Pressurisation of lift shaft found removed.
8. Detector system panel found under maintenance.
9. Battery backup found removed.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

16/2