



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-51



No. F6/DFS/MS/2024/School/ 66

Dated: 20/02/2024

To,

The Principal,
Sarvodaya Kanya Vidyalaya,
Nehru Vihar, Delhi-110054

Sub:- Regarding renewal of fire safety certificate in r/o Sarvodaya Kanya Vidyalaya (School I'd No- 1207004) located at Nehru Vihar, Delhi-110054.

Sir,

Please refer to your letter received through online e-mail dated: 03.02.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 12.02.2024 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & 03 upper floors only. At the time of inspection Smt. Meena Kumari (Vice-Principal) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Fire extinguisher provided but not functional.
2. Hose reel hose provided but not functional and damaged/leakage condition also some nozzles found missing.
3. Internal hydrant provided but not functional and badly damaged/leakage condition.
4. Terrace level fire pump capacity of 450lpm provided but found not functional & damaged condition.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully


(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.