



75
Azadi Ka
Amrit Mahotsav

C-29

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/ 61

Dated: 20/02/2024

To

The Principal,
Sarvodaya Bal Vidyalaya,
Sadiq Nagar, New Delhi-110049

Sub: Regarding renewal of Fire Safety Certificate in r/o Sarvodaya Bal Vidyalaya located at Sadiq Nagar, New Delhi-110049

Sir,

This has reference to your letter no. SBV/SN/2023-2024/149 dated 20/11/2023, on the subject cited above. In this connection, the school premises was visited by the officer concerned of this department on 09/02/2024 to verify the availability and operability of the fire protection measures provided therein in your presence. During the course of inspection, the shortcomings observed are as below.

1. The hose-reel hose found provided but non-functional (hose drum & nozzle jam).
2. The terrace pump found provided but non-functional.
3. The exit signage was not visible as all color washed.

In view of the above, the application for renewal of fire safety certificate is rejected. You are advised to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054