

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/2024/SZ/ 66
To

Dated: 20/02/2024

Mr. Prem Singh Suhag, Estate Officer,
M/s Somdatt Chambers-II, owners Association
Building No 9, Bhikaji Cama Place, New Delhi 110066

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Somdatt Chambers-II,
Owners Association at Building No 9, Bhikaji Cama Place, New Delhi 110066

Sir,

This has reference with letter no nil dated 26/10/2023, received through outdoor diary no 7832 dated 26/10/2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said building have been carried out by the officer concerned of this department on 09/02/2024 in the presence of Mr. Prem Singh Suhag, and observed to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. The Fire Check door found removed at some places.
2. Smoke management system found removed in the basement.
3. Detection system found removed in the office cabins.
4. Automatic sprinkler system not working.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE