

e/m

75
आज़ादी का
अमृत महोत्सव

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/2024/SZ/75
To

Dated: 21/02/2024

The Deputy Commissioner (Lic/Branch)
1st Floor, Police Station Defence Colony,
New Delhi 110049

Subject: Regarding issuance of Fire Safety Certificate in r/o **Adyar Ananda Bhavan Sweet India Pvt. Ltd** located at **S-16, Green Park Street, Main Market, New Delhi-110016**.

Sir,

This has a reference to MHA Portal application ID No **2024020101088** dated **03.02.2024** on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 12.02.2024 in the presence of Mr. Bala Ji and observed that building comprised of Basement + Ground + 03 upper floors, and the restaurant is to be run at ground, first and second upper floors only and following shortcomings were observed during inspection:

1. The Width of exits doors are 1.40 mtr & 1.30 mtr respectively against the required width of 1.50 mtr each.
2. The entry/exit of rear side staircase is through a kitchen, which is not acceptable.
3. Internal hydrants not provided.
4. Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

o/m n