



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/SZ/2024/ 74

Dated: 23/02/2024

To

Sh. Naresh Kumar Yadav (ASO/ Fire Officer),
Administrative Block, AIIMS,
Ansari Nagar, New Delhi-110029

Sub: **Renewal of Fire Safety Certificate in r/o Main Hospital Building (Ward Block, OPD & Old Pvt. Ward), AIIMS Complex, Ansari Nagar, New Delhi-110029**

Sir,

This has reference to the email dated 11/10/2023, on the subject cited above. In this connection, it is to inform you that the officer concerned of this department inspected the said premises on 13/02/2024 in the presence of Sh. Kumar Saurav (JE-Elect.) & Sh. Ashok Sharma (Fire Consultant). The shortcomings observed are as below.

1. Automatic fire detector found removed in lift room at terrace.
2. Exit signage at 8th floor found removed.
3. Lift No. 11 & 17 found under repair/renovation.
4. The opening of exit door at terrace floor shall be outwards.
5. Some part of 2nd Floor found under repair/renovation.
6. Electric panel found installed in escape route at 9th floor.

In view of the above, the application for renewal of Fire Safety Certificate is rejected. You are requested to rectify the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
01/02

Copy to: -

1. The Director, All India Institute of Medical Sciences, Ansari Nagar, New Delhi-110029