

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/74

Dated: 22/02/2024

To

The Authored Signatory,
Ambience Public School,
Plot No A-1, Safdarjung, Enclave,
New Delhi 110029.

Sub: -Regarding Issuance of Fire Safety Certificate in r/o M/s Ambience Public School, at Plot No A-1, Safdarjung, Enclave, New Delhi 110029.

Sir,

This has reference to your letter no nil dated 09/02/2024, received through outdoor diary no 12983 dated 12/02/2024 on the subject above. In this connection, it is to inform you that the officers concerned of this department inspected on dated 15/02/2024 in the presence of Mr. Manoj Shah to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation

1. The Self closing device in Fire Check Door found removed at some places.
2. The Smoke Management System not working in the basement.
3. Pressurization of lift lobby not working. .

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi -54