

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2024/SZ/ 76

Dated 21/02/2024

To

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor PS Defence Colony,
New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o **M/s Downtown Village**
(A Unit of Ragee Entertainment) located at Plot No 26, First Floor, Hauz Khas
Village, New Delhi 110016

Sir,

This has reference to with **MHA Portal ID 2024012500852** dated **30/01/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 14.02.2024 in the presence of Mr. Parvinder Singh to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. The 06 mtrs wide road is not available in the Village. The village has a single Entry/Exit road by which fire vehicles can go inside, however the vehicle cannot turn back/return to go for replenishment or other purposes as the road is not wide enough for turning.
2. There is one staircase having width of 1.0 mtr provided in 1st part portion & three staircases having width of 1.0m, 1.0m & 1.50 mtr provided in 2nd portion against the required two staircase having width of 1.50 mtr each portion.
3. There is one exit door having width of 1 mtr in each part portion against the required two exit door having width of 1.50 each portion
4. First Aid Hose reel hose provided but found nonfunctional.
5. Internal hydrants provided but found nonfunctional.
6. Terrace level pump capacity 450 LPM provided but found not working.
7. Overhead tank capacity 10,000 ltrs provided against the required capacity of 20,000 ltrs.
8. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The said **restaurant shall not be allowed to run in the larger interest of the public, life and safety.**

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Dy. Health Officer, Public Health Department, MCD, Aurobindo Marg, Green Park, New Delhi 110016. (Ref. MHA Portal ID 2024012500852 dated 30/01/2024)