

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2024/SZ/ 74
To

Dated 21 / 02 / 2024

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor PS Defence Colony,
New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o M/s EPIC Restro Bar located at Plot No 8A, First Floor, Hauz Khas Village, New Delhi 110016

Sir,

This has reference to with MHA Portal ID 2024012900946 dated 29/01/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 14.02.2024 in the presence of Mr. Nikhil (Manager) to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. The 06 mtrs wide road is not available in the Village. The village has a single Entry/Exit road by which fire vehicles can go inside, however the vehicle cannot turn back/return to go for replenishment or other purposes as the road is not wide enough for turning.
2. There are two staircase having width of 1.0 mtr & 1.50 mtr against the required two staircase having width of 1.50 mtr each.
3. There are two exit doors having width of 1.0 mtr against the required two exit door having width of 1.50 each.
4. First Aid Hose reel hose not provided.
5. MOEFA not provided.
6. Internal hydrants not provided.
7. Terrace level pump capacity 450 LPM not provided.
8. Overhead tank capacity 20,000 ltrs not provided.
9. Exit signage found not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The said **restaurant shall not be allowed to run in the larger interest of the public, life and safety.**

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Dy. Health Officer, Public Health Department, MCD, Aurobindo Marg, Green Park, New Delhi 110016. (Ref. MHA Portal ID 2024012900946 dated 29/01/2024)