

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI - 110001**

NO. F6/DFS/MS/SZ/2024/ 73

DATED: 22/02/2024

To,

The Principal,  
J M International School,  
Sector - 6, Dwarka, New Delhi - 110075.

**Subject: - Issuance of Fire safety Certificate in r/o J M International School, Located at Sector - 6, Dwarka, New Delhi - 110075.**

Sir,

Please refer to your letter No. FES/Fire/NOC/2023-24, dated 05/02/2024 on the subject cited above. In this connection it is to inform to you that the above said building has been inspected by the officers concerned of this department on 13/02/2024 in presence of Sh. Rohit (Admin) from fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Six m internal road around the building found not provided.
2. Fire Check Doors found not provided. Width of FCD must not be less than the width of staircases.
3. The passage to staircases found not clear.
4. Smoke management system found inadequate and not interlinked with MOEFA in basement.
5. Overhead fire water tank of capacity 5000 ltr found provided against required 25000 ltr capacity.
6. Exit signage found not provided at 4<sup>th</sup> floor.
7. Pressurization of Lift Shaft found not provided.
8. Communication system in lift car found not provided.
9. PA System Panel, Battery backup & Building Floor Plans in fire control room found not provided.
10. Fire control room found not provided.
11. Basement must be use as per BBL1983.

In view of the above shortcomings issuance of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation with this department for further consideration in the matter.

  
(Atul Garg)  
(Director)  
Delhi Fire Service  
22/2/24

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054