



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/SZ/2024/ 75

Dated: 23/02/2024

To

Sh. Naresh Kumar Yadav (ASO/ Fire Officer),
Administrative Block, AIIMS,
Ansari Nagar, New Delhi-110029

Sub: Renewal of Fire Safety Certificate in r/o Mother and Child Block, Masjid Moth, AIIMS Complex, New Delhi-110029

Sir,

This has reference to the email dated 11/10/2023, on the subject cited above. In this connection, it is to inform you that the officer concerned of this department inspected the said premises on 13/02/2024 in the presence of Sh. Vivekanand Kumar (JE-Elect.) & Sh. Ashok Sharma (Fire Consultant). The shortcomings observed are as below.

1. Smoke management system in basement found non-functional.
2. MOEFA/MCPs found provided but non-functional.
3. Automatic fire detection and alarming system at ground floor found non-functional.

In view of the above, the application for renewal of Fire Safety Certificate is rejected. You are requested to rectify the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
MC 88

Copy to: -

1. The Director, All India Institute of Medical Sciences, Ansari Nagar, New Delhi-110029