



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/SZ/2024/ 76

Dated: 23/02/2024

To

Sh. Naresh Kumar Yadav
 (ASO/ Fire Officer),
 Administrative Block, AIIMS,
 Ansari Nagar, New Delhi-110029

Sub: **Regarding issuance of Fire Safety Certificate in r/o PC Teaching Block, AIIMS Complex, Ansari Nagar, New Delhi-110029**

Sir,

This has reference to the email dated 05/02/2024, on the subject cited above. In this connection, it is to inform you that the officer concerned of this department inspected the said premises on 13/02/2024 in the presence of Sh. Ashok Sharma (Fire Consultant) and Sh. Kumar Saurav (JE-Elect.). The shortcomings observed are as below.

1. The smoke management system in basement found non-functional.
2. Basement floor still found water logged, which is safety hazard for employees/occupant and building stability as well.

In view of the above, the application for issuance of Fire Safety Certificate is rejected. You are requested to rectify the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

(ATUL GARG)
 DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Director, All India Institute of Medical Sciences, Ansari Nagar, New Delhi-110029
2. The Executive Engineer (Elect.-1), Engineering Service Department, AIIMS Complex, New Delhi-110029