



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**



C/38

No. F6/DFS/MS/WZ/2024/ 81  
To,

Dated: 22/02/2024

Sh. Abhishek Mittal,  
M/s Pizza Hut (A Unit of Devyani International Ltd.),  
B- 2/3, Ground Floor, Ashok Vihar, Ph. II,  
New Delhi- 110052.

**Sub: - Inspection report in r/o M/s. Pizza Hut ( A Unit of Devyani International Ltd.) located at B- 2/3, Ground Floor, Ashok Vihar, Phase 2, New Delhi- 110052.**

Sir,

Please refer to your online application no. 2024021301573 dated 13/02/2024 on the subject cited above. In this connection, it is to inform you that the above said building was inspected by the officer concerned by this department on 19/02/2024 in the presence of Mr. Vijay to see the compliance of shortcomings communicated vide this department letter No.F6/DFS/MS/WZ/2021/26 dated 12/01/2021.

During the course of inspection following shortcoming has been observed and status is as under:-

Sr. No	Shortcomings	Status
1.	First Aid Hose Reels not provided.	Not Rectified
2.	Terrace pump of 450 lpm not provided.	Not Rectified
3.	One no. hydrant along with RRL hose branch with nozzle and box not provided.	Not Rectified
4.	Over Head Tank of 20,000 ltrs capacity exclusive for firefighting not provided.	Not Rectified
5.	Exit signage's not provided.	Not Rectified

In view of the above shortcomings, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. You are requested to re-apply on MHA portal after compliance of above mentioned shortcomings.

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to:-

1. The Joint Commissioner of Police (Lic.), Police Station Defence Colony, First Floor, New Delhi.
2. MHA Portal ID No. 2024021301573.

1.