



C/24

75  
Azadi Ka  
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2024/SZ/77

Dated: 22/02/2024

To

The Principal,  
Rajkiya Sarvodaya Kanya Vidyalaya,  
Moti Bagh-1, New Delhi-110021

**Sub: Regarding renewal of Fire Safety Certificate in r/o Rajkiya Sarvodaya Kanya Vidyalaya located at Moti Bagh-1, New Delhi-110021 (School ID: 1719073)**

Sir,

This has reference to your letter no. SKV/MB-1/2023/513 dated 27/12/2023, on the subject cited above. In this connection, the school premises was visited by the officer concerned of this department on 12/02/2024 to verify the status of the fire safety arrangements provided therein. During the inspection Ms. Dayavati Meena (HOS) was present; the shortcomings observed are as below.

1. The hose-reel hose found provided but non-functional & nozzle missing.
2. The terrace pump found provided but non-functional.

In view of the above, the application for renewal of fire safety certificate is rejected. You are advised to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

o/c