

c/6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2024/ 79

Dated:-21..1/22/2024

To,

The Manager,
M/s Satta Vehda Luxury Restaurant,
54/8, 1st floor, D.B.G road, RD Block,
New Delhi -110005.

Sub: **Regarding issuance of FSC in r/o M/S Satta Vehda Luxury Restaurant, 54/8, 1st floor, D.B.G road, RD Block, New Delhi -110005.**

Sir,

This has reference to online id 2024012500857 dated 01/02/24, on the subject cited above. In this connection it is to inform you that the site was visited by the officer concerned of this department on 09/02/24 in the presence of Manager and observed and following shortcomings are observed.

1. Alternate staircase/ exit of 1.5 meter is not provided.
2. Separate firefighting arrangements for restaurant such as hose reel, hydrant , over head tank of 20,000 liter and pump of 450 LPM are also required.

In view of above, the case is rejected. Hence, Fire Safety Certificate (FSC) cannot be issued at this stage.

Yours faithfully


Atul Garg)
DIRECTOR
Delhi Fire Service
✓ o/c

Copy to:

The Addl. Commissioner of Police (Lic), 1st floor, Police Station, Defence Colony, New Delhi.