

C/72

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

NO. F6/DFS/MS/SZ/2024/School/76

DATED: 22/02/2024

To,

The Principal,
Shree Venkateshwar International School,
Sector 18, Dwarka, New Delhi 110075.

**Subject: - Renewal of Fire safety Certificate in r/o Shree Venkateshwar International School,
Located at Sector 18, Dwarka, New Delhi 110075.**

Sir,

Please refer to your email, dated 31/01/2024 on the subject cited above. In this connection it is to inform to you that the above said building has been re-inspected by the officers concerned of this department on 14/02/2024 in presence of Sh. Shalender Solanki (Chairman) from fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Exit signage found removed at some places.
2. The fire extinguishers found missing at some places.
3. Dully fill school detail form are not submitted.
4. Temporary rooms are seen at terrace which are being used for school activities.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation with this department for further consideration in the matter.

Copy to:-

Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

(Atul Gang)
(Director)

Delhi Fire Service

o/c

21/2/24