

C95

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
 [Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2024/8NOT/15

Dated: 27/02/2024

FIRE SAFETY CERTIFICATE

Certified that the. Shri Govindam Hall (A Unit of Gokul garden Banquets Pvt. Ltd) Located at 3rd Floor, WZ 306 – O, Khasra No. 72/6/1, Data Ram Marg, Chotiyal Palam Village, New Delhi – 110045 in a building comprised of Basement + Ground + 3 Upper Floors owned/ occupied by Gokul garden Banquets Pvt. Ltd have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 10/02/2024 in the presence of Sh. Rajeev Solanki (Director) and found that the said building that the premises is fit for occupancy class “ Assembly” Group D (At 3rd Floor only) with effect from 27/02/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/02/2024... at New Delhi by.


 Atul Garg
 Director
 Delhi Fire Service

JLC

 26/2/24

Copy to:

1. The Joint Commissioner Police, Licensing, 1st Floor, PS, Defence Colony, N Delhi.
2. Sh. Rajeev Solanki (Director) Shri Govindam Hall (A Unit of Gokul garden Banquets Pvt. Ltd) Located at 3rd Floor, WZ 306 – O, Khasra No. 72/6/1, Data Ram Marg, Chotiyal Palam Village, New Delhi – 110045.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

N-20

1. Name & address of the building: Shri Govindam Hall (A Unit of Gokul garden Banquets Pvt. Ltd) Located at 3rd Floor, WZ 306 – O, Khasra No. 72/6/1, Data Ram Marg, Chotiyal Palam Village, New Delhi – 110045
2. Type of Occupancy : **Assembly (At 3rd Floor) in a building comprised of Basement + Ground + 3 Upper Floors**
3. Type of Case : **New**
4. Details of previous NOC : **Nil**
5. Fire Safety directives Letter No. : **Nil**
6. Date of inspection : **10/02/2024**
7. Name of the Inspecting Officer : **ADO (DWK)**
8. Name and designation of Officer
from the building side : **Sh. Rajeev Solanki (Director)**
9. Year of Construction :
10. Applicant's letter No. : **Email dated 29/01/2024 & online application No. 2023120719315, dated 12/12/2023**

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 m	Provided	MR
	• Gate width	5 m	On Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	NA	Provided	NA
	b. Width of staircases			
	• Upper floors	2m & 1.5m	2.04m & 2.17m	MR
	• Basements	NA	02 Provided	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2m, 1.5m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	Provided	NA
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	05 nos.	Provided	MR
	• Types	ABC & CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required Required Required Required Required	Provided Provided Provided Provided Provided	MR MR MR MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	Provided NA NA	NA NA NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	150 mm 2 2	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	2280lpm 70m 1 180lpm 70m 2280lpm NA Required Required 900 lpm 40 m Required Required	Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided	MR MR MR MR MR MR MR MR MR MR MR MR MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Under ground tank capacity Draw of connection Fire service inlet Access to tank Overhead Tank capacity 	150000 L Required Required Required 10,000 ltrs	Provided Provided Provided Provided 10000 ltr	MR MR MR MR MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA

	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	NA	NA	
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.
 Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010.

1. Shri Govindam Hall (A Unit of Gokul garden Banquets Pvt. Ltd) Located at 3rd Floor, WZ 306 – O, Khasra No. 72/6/1, Data Ram Marg, Chotiyal Palam Village, New Delhi – 110045.
 2. As per plan submitted by the applicant the area of the Shri Govindam hall is 127.73 m²
 3. As per part IV, NBC-2016, table no 4.3 under clause 4.4.2.1 the occupant load for dining area and restaurant is 1.8. Accordingly the number of seats come out to be 71 (127.73 /1.8=71) for whole Shri Govindam hall.
- The total seating capacity comes out be 71

D.O (S.O) *[Signature]*

CFO (S2) *[Signature]*
 21/2/2024

[Signature]
 21/2/24

[Signature]

Sir Pt letter is not up for sign

"DIRECTOR" *[Signature]*
 26/2/24

[Signature]
 21/2/24
 Sign. of the Inspecting Officer
 Name Uday Kumar Singh
 Designation ADO/DW4

[Signature]
 26/2/24

26/2/24