GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2024/ 78

Dated: 26/02/2024

To,

The Principal, Govt. Middel Special (Co-ed), for the Hearing Impaired School Sector-4, Rohini, Vishram Chowk, Delhi-110085. (School Id-1413210).

Sub: Issue of FSC in r/o Govt. Middel Special (Co-ed), for the Hearing Impaired School Sector-4, Rohini, Vishram Chowk, Delhi-110085. (School Id-1413210). Sir,

Kindly reference to online mail dated 20.11.20, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 16.02.2024, in presence of Mr. Mukesh Kumar (Head-Master) to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. Alternate staircases are not continuous to terrace level on ground plus three upper blocks.

2. 02 fire extinguishers of ABC type provided against the required 15 no's of ABC / Co2 type 2.5 kg capacity required to be provided.

Hose reel not provided.

4. Terrace level fire pump capacity 450 lpm with pump head 40m not provided.

5. Overhead fire water tank capacity 10,000 ltrs not provided.

6. The required exit signage is not provided

7. Copy of approved drawings of school building may kindly be provided as the vide block is a newly constructed building.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under subrule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt p://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully

Ph; 011-23414000