



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C119
7
आज़ादी का
अमृत महोत्सव

No. F6 /DFS/MS/School/NDZ/2024/ 83

Dated: 26/02/2024

To,

The Principal
Nav Gyan Jyoti Public School
86, 1st Pusta, New Usmanpur,
Delhi-110053.

**Sub: - Regarding grant of Fire Safety Certificate in r/o Nav Gyan Jyoti Public School located at
86, 1st Pusta, New Usmanpur, Delhi-110053.**

Sir,

This has a reference to your Outdoor Diary No. 11598 dated 05.01.2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 16/02/2024 in the presence of Mr. Sandeep Kumar (Manager) and observed that building comprised of Ground + 03 upper floors.

Following shortcomings were observed during time of inspection:

1. The width of staircase shall be 1.50 meter or an additional staircase of 1.30 meter shall be provided.
2. Fire Extinguisher not provided.
3. First Aid hose reels not provided.
4. MOEFA not provided.
5. Internal hydrants not a provided
6. Access to the terrace pump and water storage tank is not provided.
7. Exit Signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to: -

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi-110054.