



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

13/2
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2024/85

Dated: 26/02/2024

To,

The Manager,
Raman Modern Public School
338, Gali No. 05, Bhagat Vihar,
Delhi - 110094.

Sub: - Regarding grant of Fire Safety Certificate in r/o Raman Modern Public School located at 338, Gali No. 05, Bhagat Vihar, Delhi-110094.

Sir,

This has a reference to your Email dated 20/11/2023, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 16/02/2024 in the presence of Mr. Rajpal Sharma (Manager) and observed that building comprised of ground plus two only. (School is running on ground plus first floor only)

Following shortcomings were observed during time of inspection:

1. First-Aid-Hose Reel provided but not functional.
2. Fire pump of 220 LPM provided but not functional.
3. Overhead tank of 5,00 liters capacity is provided against the requirement of 25,00 liters.
4. Exit Signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)

DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Manager, Raman Modern Public School located at 338, Gali No. 05, Bhagat Vihar, Delhi - 110094.
2. The Joint Director of Education, B-Block, Yamuna Vihar, Delhi - 110053.