

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6 /DFS/MS/2024/SZ/78
To

Dated: 26/02/2024

Mr. Amit Tayal (Addl. Director General)
B Wing Hudco Vishala, Bhawan,
14, Bhikaji Cama Place,
New Delhi-110066

Sub: Reg. fire Safety certificate for renovation work at O/o DG-CCI Bhikaji Cama Place,
New Delhi 110066

Sir,

This is in reference to your letter No. DG/CCI/IW/15/02/2022/98 Dated 08-02-2024 on the subject cited above. In this connection, it is to inform you that aforesaid premises have been visited by officer concern of this department on 16/02/2024 in the presence of Mohd Zakir Ali Asst. DG (CS) to verify the availability and operability of fire prevention and fire safety measures provided therein.

During the course of inspection, it was observed that the building is occupied by different govt. department. The shortcomings observed are as under;

1. Fire Check door found removed at some places in lift lobbies.
2. Smoke management system found not working.
3. First aid hose reel provided but found not working.
4. Automatic detector system found removed at some places.
5. Sprinkler system provides but found not working.
6. Fire fighting pumps are not on auto mode.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,


(AJUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Executive Engineer (Bldg.), MCD, Aurobindo Marg, Green Park, New Delhi-110016