

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/NDZ/2024/ 77

Dated:- 23 .02.2024

To,

Smt. Kalyani Raj,
Authorized Signatory,
All India Women's Conference,
Sarojini House, 6, Bhagwan Dass Road, New Delhi.

Sub:- Regarding Fire Safety Certificate in r/o All India Women's Conference at Sarojini House, 6, Bhagwan Dass Road, New Delhi.

Sir,

This has reference to your letter no. nil dated 31/01/2024, on the subject cited above. In this regard, it is to inform that the site was inspected by the officers of this department on 15/02/2024 in the presence of **Mr. Vinay Bhardwaz** and the following shortcomings were observed:-

1. Detector found nonfunctional.
2. Hydrant Coupling missing and hoses are not provided in hose boxes.
3. MOEFA found non functional.
4. Fire protection system was found removed at 1st floor, as the renovation work was going on at the said floor.

In view of above, the request for issuance of fire safety certificate FSC is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully,


(Anil Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. The Chairman, NDMC, Palika Kendra, New Delhi.

