



75
Azadi Ka
Amrit Mahotsav

C-52

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Hospital/SZ/2024/ 86

Dated: 29/02/2024

To

Sh. Naresh Kumar Yadav,
ASO/Fire Officer
Administrative Block, AIIMS,
Ansari Nagar, New Delhi-110029

Sub: Renewal of Fire Safety Certificate in r/o Burn & Plastic Unit, AIIMS near Apex Trauma Centre, New Delhi

Sir,

This has reference to the email received from ynaresh@aiims.gov.in dated 11/10/2023, on the subject cited above. In this connection, the officer concerned of this department visited the said premise on 16/02/2024 in the presence of Sh. Hingiri (JE-Elect.) to verify the status of fire safety measures provided therein. During course of inspection, the shortcomings observed are as below.

1. Water curtain found provided but non-functional.
2. Smoke management system in basement found provided but not integrated.
3. First aid hose-reel found provided but non-functional at terrace.
4. Smoke/Heat detectors found provided but non-functional.
5. The required hose-boxes near internal hydrants found provided but without branch & hoses.
6. The over-head water storage tank for fire found provided but empty.

In view of the above, the application for renewal of Fire Safety Certificate is rejected. You are requested to rectify the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Director, All India Institute of Medical Sciences, Ansari Nagar, New Delhi-110029