

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE**

No. F6/DFS/MS/BNQT/WZ/2024/ 81

Dated: 28 / 02 /2024

To,

The Authorized Signatory,  
Galaxy Automobiles Pvt. Ltd.,  
Property No. 28, DLF, Industrial Area  
Moti Nagar, New Delhi-110015.

Subject: **Regarding renewal of fire safety certificate in r/o M/s. Galaxy Automobiles Pvt. Ltd., Property No. 28, DLF Industrial Area, Moti Nagar, New Delhi-110015.**

Sir,

Please refer to your Email dated 19/02/2024, on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 19/02/2024 in the presence of Sh. Mukesh (Jha) to check the functioning of fire safety arrangements provided in the building.

During inspection, it has been observed that the said building is comprised of 03 Basement + Ground + 2 floors. Fire safety arrangements such as fire extinguishers, first-aid hose reel, MOEFA, internal hydrant, pumping arrangements, water storage tank etc. provided in the building. However, the following shortcomings were observed.

1. Fire Check doors found removed at some places.
2. Smoke management system is provided but not functional at basement & upper floors.
3. First-Aid Hose Reels is provided but not functional.
4. Automatic fire detection and alarming system is found removed.
5. MOEFA is provided but not functional.
6. Automatic Sprinkler system is provided but not functional at basement & upper floors.
7. Internal Hydrants is provided but not functional.
8. Main Pump capacity of 2850 LPM, Standby Pump capacity of 2850 LPM & jockey Pump capacity of 180 LPM is provided but not functional.
9. Under Ground tank capacity of 1,00,000 ltr & overhead tank capacity of 10,000ltr is found empty.
10. Exit Signages is found removed.
11. Pressurization of lift lobby & lift shaft is provided but not functional.

In view of above shortcomings the application for renewal of fire safety certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier. The license issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire Safety arrangements.

Yours faithfully,

(Vijay Garg)  
Director

Copy To:

1. The Executive Engineer (Bldg.) HQ, North Delhi Municipal Corporation, 8<sup>th</sup> floor, Minto Road, New Delhi.

01/02/2024  
27/02/2024