

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/GH/SZ/2024/ 74

Dated: 27/02/2024

To

The Joint Commissioner of Police (Lic.),
Police Station, Defence Colony, 1st floor,
New Delhi.

Sub:- Regarding renewal of Fire Safety Certificate in respect of M/s. Hotel Swati, 15A/56, WEA, Karol Bagh, New Delhi- 110005.

Sir,

Please refer to Online Application No. 2024021001480, dated 16.02.2024, on the subject cited above. In this connection, it is to inform you that the aforesaid guest house building was inspected by the officer concerned of this department on 22.02.2024 in the presence of Mr. Nadeem, Manager, to check the functionability of fire safety arrangements already provided in the guest house building and observed following shortcomings :-

1. Fire Check Doors are not provided.
2. CO Detectors not provided.
3. First aid hose reel found non-functional.
4. 4th floor which was earlier sealed by the owner now found occupied.

In view of the above, the renewal of fire safety certificate can not be considered at this stage. In the absence of fire safety certificate this guest house is not safe from fire safety point of view. You are requested to direct the owner/occupier to rectify the above mentioned shortcomings and apply a fresh on MHA portal for further necessary action in this matter.

Yours faithfully

(Atul Garg)
Director

Delhi Fire Service

Copy to :-

1. The owner/occupier,
M/s Hotel Swati, 15A/56,
WEA, Karol Bagh, New Delhi- 110005.