



## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Hospital/SZ/2024/ 85

Dated: 29 / 02/2024

To

Sh. Naresh Kumar Yadav, ASO/Fire Officer Administrative Block, AIIMS, Ansari Nagar, New Delhi-110029

Sub: Renewal of Fire Safety Certificate in r/o JPN Apex Trauma Centre, (AIIMS), Raj Nagar, New Delhi-110029

Sir,

This has reference to the email received from <a href="mailto:ynaresh@aiims.gov.in">ynaresh@aiims.gov.in</a> dated 14/02/2024, on the subject cited above. In this connection, the officer concerned of this department visited the said premise on 16/02/2024 in the presence of Sh. Himgiri (JE-Elect.) to verify the compliance of shortcoming issued by this department vide letter No. F.6/DFS/MS/Hospital/SZ/ 2023/4188 dated 08/11/2023 and observed that most of the shortcomings as mentioned below are yet to be complied.

- 1. Half of the smoke management system in basement found non-functional.
- 2. Hose reel provided but non-functional in Blk A.
- 3. Some of the sprinklers are above ventilation duct in basement.
- 4. The internal hydrants non-functional and rusted/corroded.
- 5. Some of the yard hydrant hose boxes without hoses and branch.
- 6. Fire pumps still not on auto mode.

In view of the above, the application for renewal of Fire Safety Certificate is rejected. You are requested to rectify the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

DÎRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Director, All India Institute of Medical Sciences, Ansari Nagar, New Delhi-110029